

096500 RESILIENT FLOORING

1. Type of resilient tile flooring shall be selected on the basis of the proposed use of the space.
2. Resilient tile flooring, if vinyl composition tile (VCT), shall be 12" by 12" by 1/8" thick, of homogeneous through-pattern construction.
3. Resilient base shall be 1/8" thick vinyl or rubber base, minimum 4" high, color throughout.
4. Stair treads shall be rubber, slip-resistant, and of a pattern that can be easily cleaned. Do not specify deeply scored patterns. The color of the stair nosing's must significantly contrast with the surfaces of treads and risers to aid navigation of the stairs by the visually impaired, both interior and exterior.
5. Contractor shall provide the University with extra stock equal to one box of resilient tile flooring for each 30 boxes or fraction thereof, of each type and color of resilient flooring installed.
6. Where existing asbestos-containing flooring materials are to be removed as hazardous material, such removal must be completed prior to the installation of new flooring by a trained and certified hazardous material abatement contractor.