

230500 MECHANICAL SOUND AND VIBRATION CONTROL

1. Design shall provide for a Noise Criteria rating in classrooms and laboratories of NC 30 or less (NC 25 is preferred).