

230700 MECHANICAL INSULATION

1. Insulation on exposed ductwork shall be rigid board type.
2. Insulation on exterior ductwork shall have PVC jacket.
3. Insulation on exterior piping shall have an aluminum jacket.
4. Insulation on all chilled water piping shall be Armaflex. Fiberglass insulation shall not be used.