

## **260530 RACEWAY AND BOXES**

1. Conduit shall be  $\frac{3}{4}$ " size minimum.
2. Provide rigid conduit under slabs.