

## **261000 TRANSFORMERS**

1. Electrical services shall utilize indoor dry type transformers in a substation arrangement.
2. KU prefers that dry type transformers not be installed above ceilings.
3. Windings shall be specified as copper; aluminum is not acceptable.
4. Dry type transformers shall be as manufactured by Square D, Siemens, Cutler Hammer, or equal.