

## **265000 LIGHTING**

1. Assure that all fixtures are accessible for repair or replacement. Prime consideration should be given to accessibility in atriums and high ceiling areas.
2. Voltage for lighting systems is not standardized, and should be determined by building voltage.
3. LED fixtures shall be specified during design and shall target 4200K as the color temperature.
4. Conference rooms, meeting rooms, classrooms, lecture spaces, etc., shall be designed with dimmable LED fixtures.
5. Lighting design levels should be in accordance with the recommendations of the Illuminating Engineering Society of North America.
6. Avoid use of emergency battery pack units for emergency lighting.
7. Exit signs should be provided with LED's.
8. Dimmer switches should be linear slide type as manufactured by Lutron, Leviton, or equal.
9. Contractor shall be responsible for disposing of old lamps and ballasts removed as part of Contractor's work. Disposal shall be in accordance with regulations of the Environmental Protection Agency. Contractor shall provide KU with written documentation giving evidence of proper disposal.