265100 - INTERIOR LIGHTING

1.01 – SECTION INCLUDES

- A. Design standards for new construction and major renovations.
- B. Occupancy Sensor locations & types
- C. Light power density limits
- D. Special Use Spaces All special use spaces are excluded from this guideline and shall be addressed on an individual basis and addressed during individual project design.

1.02 – REFERENCES

- A. Illuminating Engineering Society of North America (IESNA), Lighting Handbook, Ninth Edition
- B. ANSI/IESNA RP-3-00, Lighting for Educational Facilities
- C. ANSI/IESNA RP-16-05, Nomenclature and Definitions for Illuminating Engineering D. NECA/IESNA 500-2006, Standard for Installing Indoor Commercial Lighting System
- E. International Energy Conservation Code, latest edition

Area	Recommended Footcandle Level		CDI	CCT	Work plane Height (inches)	
	Horizontal Work plane	Vertical Work plane	CRI	CCT	Horizontal	Vertical
Auditorium						
without Desktop	10		80-100	4200 K	0	
with Desktop	30		80-100	4200 K	30	
Lounge	10	3	100	4200 K	24-36	60-78
Lobby	10	3	100	4200 K	0	60-78
Reception Area	10	3	100	4200 K	36	60-78
Conference Room						
General	30	5	80	4200 K	30	30-48
Video Conference	50	30	80	4200 K	30	30-48
Stairways and Corridors	5	10	80	4200 K	0	60-84
Classroom	30/50/100		80	4200 K	30	
White Board		5				36-60
Chalk Board		50				36-60

Art Classroom	30/50/100	30	(1)	(2)	30	36-60
Drafting	30/50/100	10	80	4200 K	30	36-60
Family Consumer Science	50	10	80	4200 K	36	60-78
Science Laboratory	50	30	80	4200 K	36-60	60-78
Lecture Hall						
Audience Area	30		80-100	4200 K	30	
Demonstration Area	100	50	80-100	4200 K	36	36-60
Music	30		80	4200 K	30	
Gymnasium						
Basketball	100	30	80	4200 K	0	110-150
Social Events	5	3	100	4200 K	0	30-78
Cafeteria Dining						
	10	3	80	4200 K	30	30-48
Cashier	30	3	80	4200 K	30	30-48
Food Display	50		80	4200 K	30	30-48
Kitchen	50	3	80	4200 K	36	36-48

Design within the following Lighting Power Density limitations as per International Energy Conservation Code (IECC) Table 505.4.2, Interior Lighting Power Allowances, latest edition:

Lighting Power Density		
Building Area Type	Watts/ft ²	
Dining: Cafeteria	1.4	
Dormitory	1.0	
Exercise Center	1.0	
Gymnasium	1.1	
Library	1.3	
Office	1.0	
Performing Arts Theater	1.6	
School/University	1.2	
Workshop	1.4	

1.03 – CONTROL UNITS

When appropriate, interior lighting circuits shall include occupancy sensors as follows -

Area	Occupancy Sensor Type	
Office	Passive Infrared, Ultrasonic, Dual Technology	
Mechanical Rooms	Dual Technology	
Dormitory General Areas	Ultrasonic	
Restrooms	Ultrasonic, Dual Technology	
Laundry	Ultrasonic	
Dwelling Area	Passive Infrared	
Study Area	Dual Technology	
Restrooms	Ultrasonic, Dual Technology	
Maintenance Shops/Custodial Areas	Dual Technology	
Storage	Passive Infrared, Ultrasonic	
Cafeteria	Passive Infrared, Ultrasonic	
Conference Room	Ultrasonic, Dual Technology	
Classroom	Ultrasonic, Dual Technology	
Closet	Passive Infrared, Ultrasonic	
Corridor	Ultrasonic, Passive infrared, Dual Technology	
Science Laboratory	Ultrasonic, Dual Technology	
Gymnasium	Dual Technology	
Lecture Hall	Dual Technology	
Library		
Reading Stacks	Ultrasonic	
Bookstack	Ultrasonic	
Lobby	Passive Infrared, Dual Technology	
Locker Room	Ultrasonic	